

ADDENDUM NO. 4**BID NO. 24-14****22 HOWARD STREET SHELL IMPROVEMENTS**

To all holders of the specifications, the following corrections are hereby made. All other items shall remain unchanged. This addendum shall become part of the Contract Documents for the above referenced project.

Acknowledgement of Addendum

Name: _____

Company: _____

Date: _____

Signature: _____

• Section 1: Specification Updates

Item 1: For purposes of roof framing, the expected weight of the (2) rooftop HVAC units is expected to be 1,000 lbs. each.

Item 2: Roof assembly insulation requires R39 Insulation.