

ADDENDUM NO. 2

**BID NO. 27-02
ABERDEEN HILLS (PHASE 2)
WATERLINE IMPROVEMENTS**

To all holders of the specifications, the following corrections are hereby made. All other items shall remain unchanged. This addendum shall become part of the Contract Documents for the above referenced project.

Acknowledgement of Addendum

Name: _____
Company: _____
Date: _____
Signature: _____

Q1: Please confirm that the Build America, Buy America (BABA) requirements do not apply to this project and that compliance with BABA is not required under the contract documents.

A1: **There are no programmatic funding requirements, such as BABA, DBE/WBE, Davis-Bacon, etc. included in the scope of this project. There are no open grant applications or third-party funding arrangements either, this project is funded solely by the City.**

Q2: Please clarify responsibility in the event that issues arise with the homeowner's existing water supply after the new service connection (tie-in) is completed. Specifically, confirm whether the contractor is responsible for repairing or replacing defects or failures in the existing homeowner-owned piping that are unrelated to the new work, or if such repairs remain the responsibility of the homeowner.

A2: **The Contractor shall not be responsible for defects or failures that are unrelated to the new work so long as the work is conducted in compliance to the Special Provisions 1.4. Specifically, the Contractor shall coordinate service line reinstatement with the property owner while doing their due diligence to avoid introducing air, debris, shock, etc. into the private plumbing.**