

ADDENDUM NO. 1

BID NO. 25-04

**SEWER REHABILITATION
ANNUAL CONTRACT**

To all holders of the specifications, the following corrections are hereby made. All other items shall remain unchanged. This addendum shall become part of the Contract Documents for the above referenced project.

Acknowledgement of Addendum

Name: _____

Company: _____

Date: _____

Signature: _____

Q1: Can a UV light cured in place pipelining process be used in place of the steam curing process, if it is equal in strength to the steam cured liner?

A1: Yes, UV can be used if it is equal in strength to the steam cured liner.