

BID ADDENDUM

Addendum No.: 6
Date: December 2, 2025
Project: Swan Meadows Water and Sewer Improvements Project
KCI Project No. 00011474_00001

Bidders must acknowledge receipt of this addendum prior to the hour and date specified for receipt of bids in the Project Conditions and Specifications or as amended, by one of the following methods: a) by completing the enclosed acknowledgement form and returning it with the bid; b) by acknowledging receipt of this addendum on each copy of the bid submitted; or c) by separate letter which includes a reference to the solicitation and addendum number. Failure of your acknowledgement to be received at the place designated for the receipt of bids prior to the hour and date specified may result in rejection of your bid.

This Addendum is hereby made a part of the Contract Documents on which the Contract will be based and shall replace, in full, the original Contract Documents. Addendum No. 6 contains the following:

I. Questions from Potential Bidders

I. Questions from Potential Bidders:

1. **Question:** We have pricing from 2 manhole suppliers. One supplier claims the City of Aberdeen requires a Dura Plate Polymer lining in all manholes. Could you please confirm if the polymer lining is required as this increases the manhole cost significantly?

Answer: No, polymer lining is not required for all manholes for this project. The City typically requires lining in all manholes however, since it was not specified in the project specifications, it will not be required for this project. The City has an ongoing manhole relining project and will include the new manholes from this project in the ongoing relining project.

PREPARED BY:



Daniel R. String, PE
Sr. Project Manager/Sr. Associate

END OF ADDENDUM #6