

ADDENDUM NO. 4**BID NO. 19-07****MIDDLETON ROAD EXTENSION
CITY OF ABERDEEN, MARYLAND**

To all holders of the specifications, the following corrections are hereby made. All other items shall remain unchanged. This addendum shall become part of the Contract Documents for the above referenced project.

Acknowledgement of Addendum

Name: _____

Company: _____

Date: _____

Signature: _____

- **Section 1: Answers to Questions Posed by Bidders**

Section 1: Answers to questions posed by bidders:

Q1: What pressure class is the C-900 PVC pipe for this project? (DR-14 or DR-18)

A1: The C-900 PVC pipe should be DR-14

Q2: How are the 6" valves on the hydrant leads to be paid?

A2: The tee, valves, pipe, and hydrant will be paid under the same hydrant bid item.