

ADDENDUM NO. 1**ITB NO. 20-07****HVAC ADDITION MAINTENANCE FACILITY
CITY OF ABERDEEN, MARYLAND**

To all holders of the specifications, the following corrections are hereby made. All other items shall remain unchanged. This addendum shall become part of the Contract Documents for the above referenced project. Include a signed copy of the addendum in your bid submission.

Acknowledgement of Addendum

Name: _____

Company: _____

Date: _____

Signature: _____

- **Section 1: Answer to Question Posed by Bidders**
- **Section 2: Pre-Bid Attendees**

Section 1:

Q1: Is the equipment listed on the bid specifications the required equipment to be installed? Or recommended equipment to be installed?

A1: The design of the cooling system was based on Mitsubishi system. An equivalent system from other manufactures can be submitted for City's engineer review and approval. It is up to the Contractor to determine if other proposed manufacturer equipment meets the engineering requirements.

Q2: Is the Contractor responsible for any electrical work?

A2: It is the Contractor's responsibility to subcontract for any required electrical work.

Q3: Is an electrical or mechanical permit required with Harford County?

A3: Yes, the contractor is expected to file for any permits for the associated work.

Q4: What is the expected completion date?

A4: The bid documents state that all work will be substantially complete by 90 calendar days after issuance of the Notice to Proceed. Final testing and acceptance of the system by the contractor will be done when external temperature conditions exist to demonstrate sufficiently to the City that the product meets the required specifications for cooling.

Section 2:

CITY OF ABERDEEN
DEPARTMENT OF PUBLIC WORKS
Sign-In Sheet

Pre-Bid Meeting: Bid 20-07 HVAC Addition Maintenance Facility
DATE: Thursday, September 26, 2019 at 2:00 PM

Name	Company	Email	Phone
Ryan Harrah	COA	rharrah@aberdeennmd.gov	410-272-1600
JEFF LAGNESH	TUSTIN	JLAGNESE@THE TUSTING GROUP	410-803-4300
Brian Gullian	Tustin	bgullian@thetustingroup.com	443 324-1683
Kyle TORSTER	CoA	KTORSTER@AberdeenMO.gov	410-272-1600

****End of Addendum No. 1****