

ADDENDUM NO. 2

BID NO. 24-03

To all holders of the specifications, the following corrections are hereby made. All other items shall remain unchanged. This addendum shall become part of the Contract Documents for the above referenced project.

Acknowledgement of Addendum

Name: _____

Company: _____

Date: _____

Signature: _____

Q1) What is the procedure for abandoning the old mains? Flow fill or cut and cap?

A1) The old main should be abandoned using a combination flowable fill and cut/cap.

Q2) In review of the road details for repairing openings in roadways, which one should be used for the trench repair- R-4, R-5, or R-6.

A2) Plate R-5 should be used for pavement trench repair. Plate W-1 should be used for pipe bedding. Backfill between pipe bedding and pavement repair should compacted CR-6 select fill.