

ADDENDUM NO. 3**BID NO. 24-03**

To all holders of the specifications, the following corrections are hereby made. All other items shall remain unchanged. This addendum shall become part of the Contract Documents for the above referenced project.

Acknowledgement of Addendum

Name: _____

Company: _____

Date: _____

Signature: _____

Q1) Can pricing for mobilization and engineering, etc be broken out into separate lines?

A1) The bid form has been updated with Line Items 006 & 007 to accommodate pricing for mobilization/demobilization, shop drawings, surveying, etc. Please see updated bid package online.

Q2) What permits will the Contractor be required to obtain?

A2) Per Title 9 3.07 and COMAR 26.03.12, water mains smaller than 16" do not require utility permitting through MDE. There will not be and City-issued utility permits or dig permits required on this project. As the Owner, the City will obtain SHA Utility Permits for modifications with State Right of Way. The Contractor will be responsible for all Miss Utility tickets and permits for traffic control.