

ARRO Consulting, Inc.
321 N. Furnace Street
Suite 200
Birdsboro, PA 19508

March 2, 2021

ADDENDUM NO. 2

**CITY OF ABERDEEN
CONTRACT 21-10
Plater Street Booster Pump Station 3rd Pump Installation
ARRO Project No. 05233.24C**

In accordance with the requirements of the “Instructions to Bidders,” this Addendum shall be attached to and become a part of the Contract Documents for the above referenced project.

Concerning the Project Manual

INSERT & REPLACE: Piping for the 3rd pump must match the original piping for Pumps No. 1 and No. 2.

“The Aurora Model 382A pump that is specified is now obsolete and replaced by the Aurora Model 382B. Please provide an Aurora Model 382B.”

BIDDERS MUST ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPECIFIED PLACE ON THE BID FORM. THE ABSENCE OF THIS ACKNOWLEDGMENT WILL BE CAUSE FOR REJECTION OF THE BID.