

February 23, 2021

ADDENDUM NO. 1

**CITY OF ABERDEEN
CONTRACT 21-10**

**Plater Street Booster Pump Station 3rd Pump Installation
Held Tuesday, February 23, 2021
ARRO Project No. 05233.24C**

In accordance with the requirements of the "Instructions to Bidders," this Addendum shall be attached to and become a part of the Contract Documents for the above referenced project.

Discussion from Pre-Bid Meeting

1. The project generally comprises of the installation of the 3rd pump and controls in the Plater St. Booster Pump Station and restoration of painted and other areas disturbed by construction operations.
2. The bids will be received at City Hall until 1:00 PM prevailing time on Thursday, March 11, 2021.
3. Questions on the bid document will be accepted until 1:00 PM prevailing time on Thursday, March 4, 2021.
4. Technical questions shall be directed by email to Jimmy Dennis at jimmy.dennis@arroconsulting.com or Bryan Panther P.E., at bryan.panther@arroconsulting.com
5. Each bid must be accompanied by bid security in the form of a bid bond, certified check or bank check for 5% of the bid total.
6. Contract times; Substantial Completion and Final Completion times will be set when the contractor is selected and the Agreement is signed (this will be based upon availability of the pump & motor, contractor shall be prepared to provide delivery date prior to signing the Agreement). There are Liquidated Damages set at \$500.00 a calendar day.
7. The bid form is a lump sum cost with no contingency items.
8. Working hours are 7:00 AM to 5:00 PM. Any request to deviation from this will need to be made in writing for review by the City.
9. The selected contractor will need to submit shop drawings to the City's Public Works Department for their review and approval.
10. The selected pump for this project is an Aurora pump as described in Section 11210.

11. The selected controls for the project shall be as described in Section 11210.
12. The selected contractor will need to coordinate work with the City's Public Works Department. Shutdowns will need to be scheduled a minimum of 2 weeks prior the scheduled shutdown.
13. The selected contractor will need to coordinate the SCADA interface work with the City's SCADA contractor. The contact info is also available in Specification Section 16961:
Data Flow Systems, Inc.
Mr. Lee White
Cell: 240.354.7024
14. There is a MDE Construction Permit that is part of the Specifications. The selected contractor will need to follow all conditions of the permit throughout construction.
15. The selected contractor will need to create "red-line as-constructed" drawings within 30 days of start-up and submit them to the City for their review and approval.

Comment by City; ARRO is the point of contact, all questions, RFIs, payment applications go first to Jimmy Dennis at jimmy.dennis@arroconsulting.com. If that becomes an issue, the City is always available if necessary.

Questions;

- *Ductile iron or welded steel pipe inside the pump station?*

The piping inside the pump station is a combination of welded steel and ductile iron, the piping needed to be installed with this project is ductile iron.

- *Can you please provide EFI information?*

Engineering Fluid Inc. (EFI)
P.O. Drawer 723
Centralia, Illinois 62801
Job Reference No. 89474-B-001.1 Tom Rainier
Riordan Materials Corp (410) 440-4411

- *Are there other bid documents than what was available from the City's website?*

No, submit the documents obtain on the website. Also, with USPS having issues, submit early or hand deliver to ensure your bid is submitted on time.

- *It is noted that there is a requirement of this Contract that Bidders shall have a minimum (5) year, (5) project documented experience in the type of Work required by this Project.*

These are universal requirements throughout the industry and will remain in place for this project.

BIDDERS MUST ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPECIFIED PLACE ON THE BID FORM. THE ABSENCE OF THIS ACKNOWLEDGMENT WILL BE CAUSE FOR REJECTION OF THE BID.

CITY OF ABERDEEN
CONTRACT 21-10
Plater St. Booster Pump Station 3rd Pump Installation
Tuesday, February 23, 2021 @ 1:00 PM
ARRO Project No. 05233.24C

Pre-Bid Sign-in Sheet

NAME	COMPANY	PHONE	EMAIL
Rolla Chng, P.E.	City of Aberdeen	(410) 272-1600	rchnng@aberdeeen-md.org
Parley Hess, P.E.	City of Aberdeen	(410) 272-1660	phess@aberdeeen-md.org
Jimmy Dennis, Engineering Specialist	ARRO Consulting, Inc.	(717) 560-6014	jimmy.dennis@arroconsulting.com
William Lort	Goettner	(410) 592-7700 @ 443-250-1392	william.lort@goettnerconstruction.com
Janel ConAton	Con-Pro Contracting	443-812-3531	Janel.ConAton@Con-Pro.com
Peter Dacey	Civil Utility Const. Co	443-504-9830	padacey@yahoo.com
Jane Dougherty	EMH	410 489 9630	emh@embenviro.com