



NOT TO SCALE

NOTES:

1. METERS TO BE SUPPLIED WITH INDIVIDUAL SERVICE LINES
2. TWIN CONNECTIONS & SHARED SERVICES NOT PERMITTED BY CITY OF ABERDEEN
3. IN TOWNHOUSE UNITS WITHOUT PERPENDICULAR PARKING, AN ADDITIONAL TWO (2) FOOT DRAINAGE AND UTILITY EASEMENT IS REQUIRED. METER VAULTS AND CLEANOUTS SHALL BE LOCATED AS SHOWN ON G-2.
4. PLACE UTILITIES ON LOW SIDE OF LOT.
5. MINIMUM SEPARATION BETWEEN WATER AND SEWER SERVICES IS SEVEN (7) FEET.
6. METER PITS AND CLEANOUTS SHALL NOT BE LOCATED IN SIDEWALKS OR STEPS.



CITY OF ABERDEEN
DEPARTMENT OF PUBLIC WORKS

Kyle Jouts

STANDARD WATER DETAILS

WATER AND SEWER SERVICES
FOR TOWNHOUSE LOTS

CITY OF ABERDEEN
ADDENDUM TO
HARFORD COUNTY
STANDARD DETAILS

PLATE **G-3**